



Eastampton Township

Fire Prevention Bureau Office of the Fire Marshal

12 Manor House Court
Eastampton, New Jersey 08060
Office: (609) 267-5723 ext. 203
Cell: (609) 676-6967
Fax: (609) 265-1714
Email: firemarshal@eastampton.com
www.Eastampton.com



5:70-2.21 Identifying emblems for structures with solar panels

(a) Identifying emblems shall be permanently affixed to the front of structures hosting or being powered by photovoltaic electrical power either on the roof or adjacent to the building.

1. The solar emblem shall be a Maltese cross shape, constructed of durable material, with a white reflective background with red letters. Numerals and letters shall be Roman or Latin as required.

1. The sign shall be six inches by six inches (152 mm by 152 mm).
2. The height or width of each Maltese cross wing area shall be one and one-eighth inches (29 mm) and have a stroke width of one-half inch (13 mm).
3. The center of the Maltese cross, a circle or oval, shall be three inches (76 mm) in diameter and have a stroke width of one-half inch (13 mm).
4. All letters and numerals shall be one and one-quarter inch (32 mm) in height and have a stroke width of one-quarter inch (six mm).
5. The letters PV shall be located in the center circle of the Maltese cross to identify the presence of solar photovoltaic systems. The wording ROOF MOUNTED *and/or* ADJACENT shall be located immediately beneath the Maltese cross identifying where the solar panels are located.

1. Premises already equipped with a truss construction sign may install the solar sign immediately above the truss sign.

Sign Designs

